



Ontario Clean Water Agency
Agence Ontarienne Des Eaux

March 17, 2008

Pat Kemp
CAO/Deputy Clerk
Township of Galway-Cavendish-Harvey
701 County Road # 36, P.O. Box 701
Bobcaygeon, ON
K0M 1A0

Re: Summary Report – Safe Drinking Water Act – Kinmount Legion Well Supply

Dear Ms. Kemp:

Attached is the 2007 Summary Report for the Kinmount Legion Well Supply. This report is completed based on the information we have in our records in accordance with Schedule 22 of O. Reg. 170/03, under the Safe Drinking Water Act, which requires a Summary Report to be prepared not later than March 31st of each year for the preceding calendar year.

After your review and inclusion of any additional information, this Summary Report is to be provided to the members of the municipal council. Please ensure this distribution.

Section 12 of O. Reg. 170/03, requires both the Summary Report and the Annual Report be made available for inspection by any member of the public during normal business hours, without charge. The reports should be made available for inspection at the office of the municipality, or at a location that is reasonably convenient to the users of the water system.

Sincerely

A handwritten signature in black ink, appearing to read "Lynette Carter".

Lynette Carter
Process Compliance Technician
Kawartha Hub
Ontario Clean Water Agency
(705) 738-9734
lcarter@ocwa.com

SUMMARY REPORTS FOR MUNICIPALITIES

Report

This report is a summary of water quality information for the Kinmount Legion Well Supply, published in accordance with Schedule 22 of Ontario's Drinking-Water Systems Regulation for the reporting period of January 1, 2007 to December 31, 2007. The Kinmount Legion Well Supply is categorized as a Small Municipal Residential Drinking Water System.

This report was prepared by The Ontario Clean Water Agency on behalf of the Township of Galway- Cavendish and Harvey.

Who gets a copy of the Report:

- in the case of a drinking-water system owned by a municipality, the members of the municipal council;
- in the case of a drinking-water system owned by a municipal service board established under section 195 of the *Municipal Act, 2001*, the members of the municipal service board; or
- in the case of a drinking-water system owned by a corporation, the board of directors of the corporation.

What must the Report contain?

The report must,

- (a) list the requirements of the Act, the regulations, the system's approval and any order that the system **failed to meet** at any time during the period covered by the report and specify the duration of the failure; and
- (b) for each failure referred to in clause (a), describe the measures that were taken to correct the failure.

The following table lists the requirements that the system failed to meet and the measures taken to correct the failure:

Drinking Water Legislation	List the requirement(s) the system failed to meet	Specify the duration of the failure (i.e. date(s))	Describe the measures taken to correct the failure	Status (complete or outstanding)
Safe Drinking Water Act	<ul style="list-style-type: none"> -The drinking water system does not provide the required minimum level of treatment at all times - A valid Certificate of Approval did not exist for the facility - Operators and Maintenance personnel did not have ready access to operations and maintenance manuals 	These issues were identified during the MOE compliance inspection on August 8, 2007	The system was fragmented.	Complete
Ontario Regulations O.Reg 170/03	-An Engineering Evaluation Report was not prepared as required.	This issues was identified during the MOE compliance inspection on August 8, 2007	The system was fragmented.	Complete

What else must the Report contain?

The report must also include the following information for the purpose of enabling the owner of the system to assess the capability of the system to meet existing and planned uses of the system:

1. A summary of the quantities and flow rates of the water supplied during the period covered by the report, including monthly average and maximum daily flows and daily instantaneous peak flow rates.
2. A comparison of the summary referred to in paragraph 1 to the rated capacity and flow rates approved in the system's approval.

The Kinmount Legion Well Supply was only able to supply water at a maximum rate of approximately 40, 000 L/day. The system was not equipped with a flow meter and the maximum rate was determined by the pump capacity. The system has since been fragmented.

When Does the Report Get Submitted?

If a report is prepared for a system that supplies water to a municipality under the terms of a contract, the owner of the system shall give a copy of the report to the municipality by March 31.

End